

SECTION- 3 Part A

SCOPE OF WORK:

TENDER FOR THE PROCUREMENT OF TWO SETS OF UPS BATTERIES

SECTION -3 Part B

TECHNICAL SPECIFICATION (Schedule of Requirement)

The equipment shall confirm the Technical specification as mentioned below

**Minimum Technical Specification for UPS**

<b>SLNO</b>	<b>Item</b>	<b>QTY</b>
<b>1</b>	<b>Each set of 30 Nos of 12 V 100 AH SMF Batteries</b>	<b>2 SETS</b>
<b>2</b>	<b>Battery rack, Battery Breaker and Battery Inter Connecting Cables</b>	<b>2 NOS</b>

The bidder should furnish the name of his collaborator (if applicable), brand name, model no and type of the product offered in this tender. The technical literatures of the products should also be submitted. No change in either technology or product shall be permitted after opening of bids.

