

BHARAT SANCHAR NIGAM LIMITED
(A Govt of India Enterprises)
(Electrical Wing)

CORRIGENDUM : 27/06/2019

O/o the Executive Engineer(E), BSNL Electrical Division – I, Ground floor, Telephone Exchange,
22, Kellys Road, Kellys, Chennai – 600 010. (Ph: 044-26470405 / 26448081) issues corrigendum for the
following work.


Name of work : Replacement of CT for effecting Reduction of Maximum Demand at TE
Kodambakkam, Chennai.

NIT NUMBER: 23/ED-I/CH/2019-20

S. N o.	Description of Item	
	As per NIT	To BE Read as
1.	Supplying and fixing of 11KV Cast resin type Current transformer of the following specification, suitable for the existing RMG Panel of MEGAWIN make, as per the requirements of TANGEDCO(for Reduction of MD from 270KVA to 190 KVA) including arranging Testing by MRT Wing (TANGEDCO) removing of old CTs and making necessary modifications,making interconnections with Bus bar alterations as required and necessary liasioning /coordination works with TANGEDCO etc. complete as required. CT Ratio:10/5-5A,Metering: 5 VA/0.2S, Protection:15VA/5P20	Supplying and fixing of 3 Nos. 11KV Cast resin type current transformer of the following specification, suitable for the existing RMG Panel of MEGAWIN make,as per the requirements of TANGEDCO(for Reduction of MD from 270KVA to 190 KVA) including arranging Testing by MRT Wing (TANGEDCO) removing of old CTs and making necessary modifications,making interconnections with Bus bar alterations as required and necessary liasioning/coordination works with TANGEDCO etc. complete as required. CT Ratio:10/5-5A,Metering: 5 VA/0.2S, Protection:15VA/5P20

All other terms and condition remains same.

For further details kindly visit our web site www.chennai.bsnl.co.in


Executive Engineer (E)
Electrical Division – I,
Chennai – 10.