

**O/o The Sub Divisional Engineer(E),**  
Electrical Sub Division-IV,  
Chennai Telephones  
TE Kellys Compound  
No.22, Kellys Road,  
Kellys,Chennai-10  
PH:26413434



No.23(NIT )/SDE(E)/ESD-IV/CH/2021/

Dt:01/02//2021

## **CORRIGENDUM**

**NIT No 50/ED-I/CH/15-16 Dt.: 06/02/2021**

**Name of Work : Shifting of 2nos.1.5TR S/T AC unit and Misc.Electrical works due to shifting of DLC from Sri Krishna sweets,Nemam to New Location,Chennai.**

<b>Sl.no</b>	<b>EXISTING ENTRY</b>	<b>MAY BE READ AS</b>
1	Earthing with Copper. earth plate 600 mm X 600 mm X 6 mm thick including accessories, and providing masonry enclosure with cover plate having locking arrangement and watering pipe of 2.7 metre long etc. with charcoal/ coke and salt as required.	Earthing with Copper. earth plate 600 mm X 600 mm X 3mm thick including accessories, and providing masonry enclosure with cover plate having locking arrangement and watering pipe of 2.7 metre long etc. with charcoal/ coke and salt as required.

**SUB DIVISIONAL ENGINEER(E)**

